

Certificate of Compliance

Certificate Number **20110523 R25079**
Report Reference **R25079 2006 March 20**
Issue Date **2011 May 23**

Page 1 of 3



Issued to: **ARABIAN THERMAL AIRE INDUSTRIES CO LTD**

PO BOX 10125, MADINAT, AL-JUBAIL
AL-SINAIYAH, 31961 SAUDI ARABIA

*This is to certify that
representative samples of*

Dampers for Fire Barrier and Smoke Applications


For model information please refer to the addendum

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: **UL 555, Seventh Edition dated 2006-07-12 with revisions dated 2010-05-04.**

Additional Information: **See UL On-Line Certification Directory at www.UL.com for additional
Information.**

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product

William R. Carney,

Director of the North American Certification Program.

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark Services are provided on behalf of Underwriters Laboratories Inc (UL) or any authorized licensee of UL.
For questions in India, you may call 91-80-4138 4400, UL India pvt. Ltd.

Certificate of Compliance

Certificate Number **20110523 R25079**
 Report Reference **R25079 2006 March 20**
 Issue Date **2011 May 23**



**Underwriters
Laboratories Inc.®**

Page 2 of 3

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Fire Dampers for Use in Static Systems

Model	Hr Class	Damper Mounting Position	Single Section Damper Size, in.		Multiple Section Damper Size, in.	
			W	H	W	H
AFD-R2-GS	1-1/2	H, V	33	36	—	—
AFD-R2-SS	1-1/2	H, V	33	36	—	—
AFD-R5	1-1/2	V	36	48	72	96
AFD-R2-GS-C1 & AFD-R2-SS-C1,	1-1/2	H, V	33	36	—	—
AFD-R2-GS-C2 & AFD-R2-SS-C2,	1-1/2	H, V	33	36	—	—
AFD-R2-GS-3 & AFD-R2-SS-3	1-1/2	H, V	33	36	—	—
AFD-R2-GS-4 & AFD-R2-SS-4	1-1/2	H, V	33	36	—	—
WF	1-1/2	V	36	48	72	96

William R. Carney,

Director of the North American Certification Program.

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark Services are provided on behalf of Underwriters Laboratories Inc (UL) or any authorized licensee of UL.
 For questions in India, you may call 91-80-4138 4400, UL India pvt. Ltd.

Certificate of Compliance

Certificate Number **20110523 R25079**
Report Reference **R25079 2006 March 20**
Issue Date **2011 May 23**

Page 3 of 3



**Underwriters
Laboratories Inc.®**

Combination Fire and Smoke Dampers

Dampers rated 2000 fpm / 4.0 in. WC:

Model	Hr Class	Leakage Class	Damper Mounting Position	Single Section Damper Size, in.				Multiple Section Damper Size, in.	
				W		H		W	H
				Min	Max	Min	Max		
AFSD-R5	1-1/2	III - 250	V	8	36	8	48	72	48

William R. Carney,

Director of the North American Certification Program.

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark Services are provided on behalf of Underwriters Laboratories Inc (UL) or any authorized licensee of UL.
For questions in India, you may call 91-80-4138 4400, UL India pvt. Ltd.